



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003628
Project #: SFIS #: 3039

Tuesday, July 19, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Assumption College

Attn : Paul Viszy (PWBS)

Date Rec. : 12 July 2011
LR Report: CA19045-JUL11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	15-Jul-11
2: Analysis Start Time		--	22:19
3: Analysis Approval Date		--	19-Jul-11
4: Analysis Approval Time		--	09:03
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Fountain Ext Rm 2063	06-Jul-11 01:18	16.0	5.31
8: TAP Flushed - Fountain Ext Rm 2063	06-Jul-11 02:00	16.0	2.74

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003641
Project #: SFIS #: 3069

Thursday, July 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Blessed Sacrament

Attn : Paul Viszy (PWBS)

Date Rec. : 30 June 2011
LR Report: CA19234-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	07-Jul-11
2: Analysis Start Time		--	09:15
3: Analysis Approval Date		--	07-Jul-11
4: Analysis Approval Time		--	11:52
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Rm 125	25-Jun-11 09:03	11.0	127 MAC
8: TAP Flushed -Rm 125	25-Jun-11 09:38	11.0	1.40

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500155728
Project #: SFIS #: 6415

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Catholic Ed Ctre

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19173-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:30
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Kitchen	18-Jun-11 12:43	13.0	1.31
8: TAP Flushed -Kitchen	18-Jun-11 13:18	13.0	0.67

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003654
Project #: SFIS #: 3131

Thursday, May 26, 2011

Brant Haldimand Norfolk DCSB (Reg243) Christ the King

Attn : Don Zelem

Date Rec. : 19 May 2011
LR Report: CA19055-MAY11

PO Box 217, 322 Fairview Dr.
Brantford, ON
N3T 5M8,

Copy: #1

Phone: 519-759-3555 ext 125
Fax:519-759-7611

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	25-May-11
2: Analysis Start Time		--	10:52
3: Analysis Approval Date		--	26-May-11
4: Analysis Approval Time		--	08:07
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Nurse's Room	12-May-11 21:16	14.0	2.35
8: TAP Flushed - Nurse's Room	12-May-11 21:56	14.0	1.11

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003667
Project #: SFIS #: 3271

Wednesday, June 15, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Holy Cross

Attn : Paul Viszy (PWBS)

Date Rec. : 10 June 2011
LR Report: CA19051-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	14-Jun-11
2: Analysis Start Time		--	15:27
3: Analysis Approval Date		--	15-Jun-11
4: Analysis Approval Time		--	07:26
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Rm. 128 Fountain	04-Jun-11 12:53	16.0	4.03
8: TAP Flushed - Rm. 128 Fountain	04-Jun-11 13:33	16.0	2.58

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500000274
Project #: SFIS #: 3296

Thursday, July 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Holy Family
 Attn : Paul Viszy (PWBS)

Date Rec. : 30 June 2011
LR Report: CA19237-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	07-Jul-11
2: Analysis Start Time		--	09:15
3: Analysis Approval Date		--	07-Jul-11
4: Analysis Approval Time		--	11:51
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Rm 155 Sink	26-Jun-11 14:43	11.0	2.88
8: TAP Flushed -Rm 155 Sink	26-Jun-11 15:18	11.0	9.26

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009023
Project #: SFIS #: 10117

Wednesday, June 15, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Holy Trinity HS

Attn : Paul Viszy (PWBS)

Date Rec. : 10 June 2011
LR Report: CA19054-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	14-Jun-11
2: Analysis Start Time		--	15:27
3: Analysis Approval Date		--	15-Jun-11
4: Analysis Approval Time		--	07:26
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Servery	04-Jun-11 12:12	16.0	2.05
8: TAP Flushed - Servery	04-Jun-11 12:50	16.0	0.84

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500210601
Project #: SFIS #: 11312

Thursday, July 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Jean Vanier
 Attn : Paul Viszy (PWBS)

Date Rec. : 30 June 2011
LR Report: CA19232-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1


Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	07-Jul-11
2: Analysis Start Time		--	09:15
3: Analysis Approval Date		--	07-Jul-11
4: Analysis Approval Time		--	11:52
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Kindergarten 1-102 Fountain	25-Jun-11 06:59	11.0	0.75
8: TAP Flushed -Kindergarten 1-102 Fountain	25-Jun-11 07:34	11.0	1.59

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit



Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003680
Project #: SFIS #:3480

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Brantford

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19172-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:31
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain Ext Rm 1078	19-Jun-11 10:03	13.0	3.24
8: TAP Flushed -Fountain Ext Rm 1078	19-Jun-11 10:45	13.0	1.88

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500124827
Project #: SFIS #: 6104

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Caledonia

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19099-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	09:49
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:37
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Fountain by Rm #122	11-Jun-11 14:13	13.0	0.25
8: TAP Flushed - Fountain by Rm #122	11-Jun-11 14:46	13.0	0.15

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009062
Project #: SFIS #: 3522

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Our Lady of Fatima-Courtland

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19162-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:32
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Rm 103	18-Jun-11 10:46	13.0	2.00
8: TAP Flushed -Rm 103	18-Jun-11 11:21	13.0	0.52

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - KOL 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003875
Project #: SFIS #: 10005

Monday, June 06, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Our Lady of Providence

Attn : Paul Viszy (PWBS)

Date Rec. : 01 June 2011
LR Report: CA19118-MAY11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	06-Jun-11
2: Analysis Start Time		--	10:14
3: Analysis Approval Date		--	06-Jun-11
4: Analysis Approval Time		--	13:06
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Fountain @ Rm 165	29-May-11 14:46	21.0	4.16
8: TAP Flushed - Fountain @ Rm 165	29-May-11 15:21	21.0	0.89

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009010
Project #: SFIS #: 3536

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Our Lady of LaSalette

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19081-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	11:13
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:45
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Drinking Fountain - Ext. Room 129	12-Jun-11 13:17	13.0	0.24
8: TAP Flushed - Drinking Fountain - Ext. Room 129	12-Jun-11 13:52	13.0	0.14

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003719
Project #: SFIS #: 3616

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Ressurrection

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19179-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:28
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain Ext Rm 140	18-Jun-11 09:35	13.0	1.61
8: TAP Flushed -Fountain Ext Rm 140	18-Jun-11 10:10	13.0	1.39

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003745
Project #: SFIS #: 3660

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Sacred Heart

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19168-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:32
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -GR1	18-Jun-11 11:38	13.0	6.04
8: TAP Flushed -GR1	18-Jun-11 12:18	13.0	1.88

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - KOL 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500170522
Project #: SFIS #: 11052

Thursday, July 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Sacred Heart Paris

Attn : Paul Viszy (PWBS)

Date Rec. : 30 June 2011
LR Report: CA19241-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	07-Jul-11
2: Analysis Start Time		--	09:15
3: Analysis Approval Date		--	07-Jul-11
4: Analysis Approval Time		--	11:51
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Kindergarten Rm 168 Sink	26-Jun-11 13:45	11.0	1.78
8: TAP Flushed -Kindergarten Rm 168 Sink	26-Jun-11 14:20	11.0	1.00

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500001327
Project #: SFIS #: 3763

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Anthony Daniel

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19079-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	11:13
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:45
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Room 129 Drinking Fountain	11-Jun-11 10:37	13.0	5.04
8: TAP Flushed - Room 129 Drinking Fountain	11-Jun-11 11:16	13.0	2.92

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003758
Project #: SFIS #: 3813

Monday, June 06, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Bernard

Attn : Paul Viszy (PWBS)

Date Rec. : 31 May 2011
LR Report: CA19120-MAY11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	06-Jun-11
2: Analysis Start Time		--	10:14
3: Analysis Approval Date		--	06-Jun-11
4: Analysis Approval Time		--	13:06
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Main Entry Fountain	29-May-11 13:14	21.0	3.08
8: TAP Flushed - Main Entry Fountain	29-May-11 13:49	21.0	2.52

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - KOL 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009075
Project #: SFIS #: 3810

Tuesday, June 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Bernard of Clairvaux

Attn : Paul Viszy (PWBS)

Date Rec. : 31 May 2011
LR Report: CA19133-MAY11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	06-Jun-11
2: Analysis Start Time		--	12:12
3: Analysis Approval Date		--	07-Jun-11
4: Analysis Approval Time		--	10:20
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Room 144	28-May-11 10:32	19.0	4.96
8: TAP Flushed - Room 144	28-May-11 11:07	19.0	1.55

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008997
Project #: SFIS #: 3842

Wednesday, June 15, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Cecilia
Attn : Paul Viszy (PWBS)

Date Rec. : 10 June 2011
LR Report: CA19052-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	14-Jun-11
2: Analysis Start Time		--	15:27
3: Analysis Approval Date		--	15-Jun-11
4: Analysis Approval Time		--	07:26
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Rm. 128	04-Jun-11 13:50	16.0	3.22
8: TAP Flushed - Rm. 128	04-Jun-11 14:25	16.0	1.48

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008984
Project #: SFIS #: 3927

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Francis of Cabrini

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19083-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	11:13
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:36
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Drinking Fountain - Ext. Room 09	12-Jun-11 13:56	13.0	3.54
8: TAP Flushed - Drinking Fountain - Ext. Room 09	12-Jun-11 14:33	13.0	4.63

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003888
Project #: SFIS #: 10395

Tuesday, July 19, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Gabriel

Attn : Paul Viszy (PWBS)

Date Rec. : 12 July 2011
LR Report: CA19044-JUL11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	15-Jul-11
2: Analysis Start Time		--	22:19
3: Analysis Approval Date		--	19-Jul-11
4: Analysis Approval Time		--	09:03
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Rm 116	06-Jul-11 12:21	16.0	1.11
8: TAP Flushed - Rm 116	06-Jul-11 12:57	16.0	0.61

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003706
Project #: SFIS #: 3600

Tuesday, July 12, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St John's College

Attn : Paul Viszy (PWBS)

Date Rec. : 08 July 2011
LR Report: CA19021-JUL11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	11-Jul-11
2: Analysis Start Time		--	17:21
3: Analysis Approval Date		--	12-Jul-11
4: Analysis Approval Time		--	12:37
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Rm 2006	04-Jul-11 07:09	14.0	4.24
8: TAP Flushed -Rm 2006	04-Jul-11 07:54	14.0	2.03

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009036
Project #: SFIS #: 4118

Wednesday, June 15, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Joseph
Attn : Paul Viszy (PWBS)

Date Rec. : 10 June 2011
LR Report: CA19053-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	14-Jun-11
2: Analysis Start Time		--	15:27
3: Analysis Approval Date		--	15-Jun-11
4: Analysis Approval Time		--	07:26
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Rm. 107	04-Jun-11 09:00	16.0	4.57
8: TAP Flushed - Rm. 107	04-Jun-11 09:35	16.0	2.16

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - KOL 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003784
Project #: SFIS #: 4164

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Leo
 Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19177-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:27
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain Ext Rm 110	18-Jun-11 08:52	13.0	1.48
8: TAP Flushed -Fountain Ext Rm 110	18-Jun-11 09:27	13.0	1.48

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003797
Project #: SFIS #: 4265

Wednesday, June 15, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Mary

Attn : Paul Viszy (PWBS)

Date Rec. : 10 June 2011
LR Report: CA19050-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	14-Jun-11
2: Analysis Start Time		--	15:27
3: Analysis Approval Date		--	15-Jun-11
4: Analysis Approval Time		--	07:25
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Room 116	04-Jun-11 14:08	16.0	3.11
8: TAP Flushed - Room 116	04-Jun-11 14:43	16.0	4.31

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008971
Project #: SFIS #: 4285

Monday, June 06, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Mary Hagersville

Attn : Paul Viszy (PWBS)

Date Rec. : 01 June 2011
LR Report: CA19124-MAY11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	06-Jun-11
2: Analysis Start Time		--	10:14
3: Analysis Approval Date		--	06-Jun-11
4: Analysis Approval Time		--	13:06
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Kindergarden Room	28-May-11 13:05	21.0	1.50
8: TAP Flushed - Kindergarden Room	28-May-11 13:42	21.0	1.60

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008958
Project #: SFIS #: 4319

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Michael Dunnville

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19093-JUN11

237 Elgin St.
Brantford, ON
N3S 5A8,

Copy: #1


Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	09:49
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:37
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Fountain Rm #154	11-Jun-11 08:08	13.0	2.00
8: TAP Flushed - Fountain Rm #154	11-Jun-11 08:46	13.0	1.40

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit



Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009049
Project #: SFIS #: 4318

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Michael Simcoe

Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19163-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:32
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain By Rm 138	18-Jun-11 15:48	13.0	3.40
8: TAP Flushed -Fountain By Rm 138	18-Jun-11 16:20	13.0	3.46

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003823
Project #: SFIS #: 4365

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Patrick Caledonia

Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19096-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	09:49
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:37
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Fountain by Rm #125	11-Jun-11 15:11	13.0	0.92
8: TAP Flushed - Fountain by Rm #125	11-Jun-11 15:46	13.0	0.54

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003810
Project #: SFIS #: 4364

Monday, June 27, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Patrick
 Attn : Paul Viszy (PWBS)

Date Rec. : 23 June 2011
LR Report: CA19174-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	24-Jun-11
2: Analysis Start Time		--	09:48
3: Analysis Approval Date		--	27-Jun-11
4: Analysis Approval Time		--	08:30
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain Ext Rm 118	18-Jun-11 12:57	13.0	28.1 MAC
8: TAP Flushed -Fountain Ext Rm 118	18-Jun-11 13:33	13.0	8.41

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

 Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003836
Project #: SFIS #: 4411

Tuesday, May 31, 2011

Brant Haldimand Norfolk DCSB (Reg243) St Peter

Attn : Don Zelem

Date Rec. : 26 May 2011
LR Report: CA19105-MAY11

PO Box 217, 322 Fairview Dr.
Brantford, ON
N3T 5M8,

Copy: #1

Phone: 519-759-3555 ext 125
Fax:519-759-7611

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	30-May-11
2: Analysis Start Time		--	15:44
3: Analysis Approval Date		--	31-May-11
4: Analysis Approval Time		--	10:07
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Room #3 Fountain	23-May-11 12:55	10.0	0.94
8: TAP Flushed - Room #3 Fountain	23-May-11 13:30	10.0	1.17

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008945
Project #: SFIS #: 4429

Tuesday, May 31, 2011

Brant Haldimand Norfolk DCSB (Reg243) St Pius X

Attn : Don Zelem

Date Rec. : 26 May 2011
LR Report: CA19102-MAY11

PO Box 217, 322 Fairview Dr.
Brantford, ON
N3T 5M8,

Copy: #1

Phone: 519-759-3555 ext 125
Fax:519-759-7611

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	30-May-11
2: Analysis Start Time		--	15:44
3: Analysis Approval Date		--	31-May-11
4: Analysis Approval Time		--	10:07
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Room #117	23-May-11 15:47	10.0	1.29
8: TAP Flushed - Room #117	23-May-11 16:28	10.0	2.62

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Please Note: Sampling time was not written on the chain of custody or bottle labels.

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003849
Project #: SFIS #: 4469

Tuesday, June 21, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Stephen
 Attn : Paul Viszy (PWBS)

Date Rec. : 17 June 2011
LR Report: CA19101-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	20-Jun-11
2: Analysis Start Time		--	11:13
3: Analysis Approval Date		--	21-Jun-11
4: Analysis Approval Time		--	11:37
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing - Rm #136	11-Jun-11 12:14	13.0	3.48
8: TAP Flushed - Rm #136	11-Jun-11 12:54	13.0	1.17

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003862
Project #: SFIS #: 4489

Thursday, July 07, 2011

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Theresa

Attn : Paul Viszy (PWBS)

Date Rec. : 30 June 2011
LR Report: CA19227-JUN11

237 Elgin St.
 Brantford, ON
 N3S 5A8,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		--	07-Jul-11
2: Analysis Start Time		--	09:15
3: Analysis Approval Date		--	07-Jul-11
4: Analysis Approval Time		--	11:52
5: MAC		--	10
6: MDL		--	0.02
7: TAP Standing -Fountain Room 105	25-Jun-11 08:32	11.0	3.48
8: TAP Flushed - Fountain Roo 105	25-Jun-11 09:07	11.0	2.24

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Kimberley Didsbury
 Project Specialist
 Environmental Services, Analytical