

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003628**Project :** SFIS #: 3039

19-June-2017

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) Assumption College****Attn :** Paul Viszy (PWBS)**Date Rec. :** 06 June 2017**LR Report:** CA19071-JUN17

174 Stanley St. Unit 300  
Brantford, ON  
N3S 7S3,

**Copy:** #1

Phone: 519-753-3266

Fax: 519-753-7072

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	13:30
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	16:15
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Lobby 1040 Drinking Spout	03-Jun-17 07:25	19.4	0.02
8: TAP Flushed - Lobby 1040 Drinking Spout	03-Jun-17 08:05	19.4	0.03
9: TAP Standing - Cor 1029 Fountain	03-Jun-17 07:25	19.4	0.62
10: TAP Flushed - Cor 1029 Fountain	03-Jun-17 08:05	19.4	0.43
11: TAP Standing - Cor 1012 Fountain	03-Jun-17 07:25	19.4	0.65
12: TAP Flushed - Cor 1012 Fountain	03-Jun-17 08:05	19.4	0.58
13: TAP Standing - Cor 1064 Drinking Spout	03-Jun-17 07:25	19.4	0.01 <MDL
14: TAP Flushed - Cor 1064 Drinking Spout	03-Jun-17 08:05	19.4	0.01 <MDL
15: TAP Standing - Cor 1112 Fountain	03-Jun-17 07:25	19.4	8.44
16: TAP Flushed - Cor 1112 Fountain	03-Jun-17 08:05	19.4	3.31
17: TAP Standing - Cor 1087 Fountain	04-Jun-17 07:30	19.4	0.74
18: TAP Flushed - Cor 1087 Fountain	04-Jun-17 08:10	19.4	0.31
19: TAP Standing - Cor 1065 Fountain	04-Jun-17 07:30	19.4	0.48
20: TAP Flushed - Cor 1065 Fountain	04-Jun-17 08:10	19.4	0.25

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

**Patti Stark****Project Specialist Environmental Services,  
Analytical**

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003628**Project :** SFIS #: 3039**LR Report :** CA19071-JUN17

## Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006