



**SGS Canada Inc.**  
P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500286079  
**Project #:** SFIS #:14365

31-May-2016

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) St. Basils**

Attn : Paul Viszy (PWBS)

535 Paris Rd..  
Paris, ON  
N3L 3E1,

Phone: 519-753-3266  
Fax:519-753-7072

**Date Rec. :** 25 May 2016  
**LR Report:** CA19173-MAY16  
**Reference:** co-located w/ Walter Gretzky

**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	27-May-16
2: Analysis Start Time		---	13:21
3: Analysis Approval Date		---	27-May-16
4: Analysis Approval Time		---	13:32
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - St.B-side Room 2030	22-May-16 06:17	22.4	0.18
8: TAP Flushed - St.B-side Room 2030	22-May-16 06:52	22.4	0.19
9: TAP Standing - St.B-side Room 1037-Fountain	22-May-16 06:25	22.4	0.01 <MDL
10: TAP Flushed - St.B-side Room 1037-Fountain	22-May-16 07:00	22.4	0.02
11: TAP Standing - St.B-side Room 2056-Fountain	22-May-16 06:18	22.4	0.01 <MDL
12: TAP Flushed - St.B-side Room 2056-Fountain	22-May-16 06:53	22.4	0.02
13: TAP Standing - Walt.G-side Room 1018	22-May-16 06:25	22.4	0.34
14: TAP Flushed - Walt.G-side Room 1018	22-May-16 07:00	22.4	0.18
15: TAP Standing - Walt.G-side Room 2055-Fountain	22-May-16 06:17	22.4	0.02
16: TAP Flushed - Walt.G-side Room 2055-Fountain	22-May-16 06:52	22.4	0.02
17: TAP Standing - Walt.G-side Room 1021-Fountain	22-May-16 06:25	22.4	0.01
18: TAP Flushed - Walt.G-side Room 1021-Fountain	22-May-16 07:00	22.4	0.06

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500286079  
**LR Report :** CA19173-MAY16  
**Project #:** SFIS #:14365

### Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8