



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003641

Project : SFIS #: 3069

26-May-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Blessed Sacrament

Attn : Paul Viszy (PWBS)

Date Rec. : 16 May 2017

LR Report: CA19176-MAY17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	23-May-17
2: Analysis Start Time		---	12:37
3: Analysis Approval Date		---	23-May-17
4: Analysis Approval Time		---	13:47
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Fount. by Kinder	13-May-17 14:21	18.0	0.01 <MDL
8: TAP Flushed - Fount. by Kinder	13-May-17 15:00	18.0	0.01 <MDL
9: TAP Standing - Bottle Fill St. by Room 121	13-May-17 14:23	18.0	0.01 <MDL
10: TAP Flushed - Bottle Fill St. by Room 121	13-May-17 15:01	18.0	0.01 <MDL

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical