



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500155728
Project #: SFIS #: 6415

10-May-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Catholic Ed Ctre

Attn : Paul Viszy (PWBS)

Date Rec. : 04 May 2016
LR Report: CA15062-MAY16

535 Paris Rd..
 Paris, ON
 N3L 3E1,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	09-May-16
2: Analysis Start Time		---	10:33
3: Analysis Approval Date		--	09-May-16
4: Analysis Approval Time		--	12:02
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing Kitchen	03-May-16 05:00	11.0	0.72
8: TAP Flushed Kitchen	03-May-16 05:35	11.0	0.28

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

Patti Stark
 Project Specialist Environmental Services,
 Analytical