



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500155728

**Project :** SFIS #: 6415

01-June-2017

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) Catholic Ed Ctre**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 26 May 2017

**LR Report:** CA19249-MAY17

174 Stanley St. Unit 300  
Brantford, ON  
N3S 7S3,

**Copy:** #1

Phone: 519-753-3266  
Fax:519-753-7072

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt at London Lab °C	Lead ug/L
1: Analysis Start Date			29-May-17
2: Analysis Start Time			11:00
3: Analysis Approval Date			29-May-17
4: Analysis Approval Time			14:22
5: MAC			10
6: MDL			0.01
7: TAP Standing-Room 154 Drinking Spout	20-May-14:03	21.0	0.01 <MDL
8: TAP Flushed-Room 154 Drinking Spout	20-May-14:38	21.0	0.01 <MDL
9: TAP Standing-Room 141 Drinking Spout	20-May-14:03	21.0	0.01 <MDL
10: TAP Flushed-Room 141 Drinking Spout	20-May-14:38	21.0	0.01 <MDL

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Patti Stark**  
*Project Specialist Environmental Services,  
Analytical*