



**SGS Canada Inc.**  
P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003654  
**Project #:** SFIS #: 3131

02-June-2016

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) Christ the King**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 31 May 2016  
**LR Report:** CA19232-MAY16

535 Paris Rd..  
Paris, ON  
N3L 3E1,

**Copy:** #1

Phone: 519-753-3266  
Fax:519-753-7072

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	02-Jun-16
2: Analysis Start Time		---	10:09
3: Analysis Approval Date		---	02-Jun-16
4: Analysis Approval Time		---	13:19
5: MAC		---	10
6: MDL		---	0.02
7: TAP Standing - Room 210	26-May-16 05:03	24.1	3.27
8: TAP Flushed - Room 210	26-May-16 05:45	24.1	1.00

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

#### Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical