

SGS Canada Inc. P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365 Works #: 500003654 Project : SFIS #: 3131

01-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Christ the King

Attn : Paul Viszy (PWBS)

Date Rec. : 26 May 2017 LR Report: CA19254-MAY17

Copy: #1

Phone: 519-753-3266 Fax:519-753-7072

174 Stanley St. Unit 300

Brantford, ON N3S 7S3,

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt at London Lab °C	Lead ug/L
1: Analysis Start Date			29-May-17
2: Analysis Start Time			11:00
3: Analysis Approval Date			01-Jun-17
4: Analysis Approval Time			13:35
5: MAC			10
6: MDL			0.01
7: TAP Standing-Corridor 202 Drinking Spout	20-May-17 12:12	21.0	0.02
8: TAP Flushed-Corridor 202 Drinking Spout	20-May-17 12:54	21.0	0.01 <mdl< td=""></mdl<>
9: TAP Standing-Cor 202 Bottle Filler	20-May-17 19:05	21.0	0.01
10: TAP Flushed-Cor 202 Bottle Filler	20-May-17 19:47	21.0	0.01

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Ja, K

Patti Stark Project Specialist Environmental Services, Analytical

0001017934