



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500000274

Project : SFIS #: 3296

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Holy Family

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19060-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	16-Jun-17
2: Analysis Start Time		---	12:50
3: Analysis Approval Date		---	15-Jun-17
4: Analysis Approval Time		---	09:59
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing- Fountain Corridor 152 by Room 164 spout	27-May-17 06:54	19.4	0.02
8: TAP Flushed -Fountain Corridor 152 by Room 164 spout	27-May-17 07:29	19.4	0.01 <MDL
9: TAP Standing -Fountain Cor 152 by Room 118	27-May-17 06:54	19.4	0.01 <MDL
10: TAP Flushed -Fountain Cor 152 by Room 118	27-May-17 07:29	19.4	0.01 <MDL
11: TAP Standing -Room 129 Fountain	27-May-17 06:54	19.4	0.62
12: TAP Flushed -Room 129 Fountain	27-May-17 07:29	19.4	0.26

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical