



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500210601
Project #: SFIS #: 11312

02-June-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Jean Vanier

Attn : Paul Viszy (PWBS)

Date Rec. : 31 May 2016
LR Report: CA19223-MAY16

535 Paris Rd..
 Paris, ON
 N3L 3E1,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature upon Delivery @ London Lab °C | Lead ug/L |
|--|--------------------|---|-----------|
| 1: Analysis Start Date | | --- | 02-Jun-16 |
| 2: Analysis Start Time | | --- | 10:09 |
| 3: Analysis Approval Date | | --- | 02-Jun-16 |
| 4: Analysis Approval Time | | --- | 13:17 |
| 5: MAC | | --- | 10 |
| 6: MDL | | --- | 0.02 |
| 7: TAP Standing - Kindergarten #3 Rm 106 | 28-May-16 08:59 | 24.1 | 0.28 |
| 8: TAP Flushed - Kindergarten #3 Rm 106 | 28-May-16 09:34 | 24.1 | 0.33 |

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

| Parameter | Description | SGS Method Code | Reference Method Code |
|-----------|-------------------------------|---------------------------|-----------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 | SM 3030/EPA 200.8 |

Patti Stark
 Project Specialist Environmental Services,
 Analytical