



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500210601

Project : SFIS #: 11312

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Jean Vanier

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19058-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	13:30
3: Analysis Approval Date		---	15-Jun-17
4: Analysis Approval Time		---	09:58
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing- Room 105 Fountain	27-May-17 10:05	19.4	0.16
8: TAP Flushed - Room 105 Fountain	27-May-17 10:40	19.4	0.10
9: TAP Standing - Room 106 Fountain	27-May-17 10:05	19.4	0.19
10: TAP Flushed - Room 106 Fountain	27-May-17 10:40	19.4	0.21
11: TAP Standing - Cor. 121 Room by 127 Spout	27-May-17 10:05	19.4	0.01
12: TAP Flushed - Cor 121 Room by 127 Spout	27-May-17 10:40	19.4	0.01
13: TAP Standing - Corr 205 Fountain Spout by Rm 217	30-May-17 05:42	19.4	0.02
14: TAP Flushed - Corr 205 Fountain Spout by Rm 217	30-May-17 06:18	19.4	0.02

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical