



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003784

Project : SFIS #: 4164

01-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Leo

Attn : Paul Viszy (PWBS)

Date Rec. : 26 May 2017

LR Report: CA19255-MAY17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt at London Lab °C	Lead ug/L
1: Analysis Start Date			01-Jun-17
2: Analysis Start Time			10:12
3: Analysis Approval Date			01-Jun-17
4: Analysis Approval Time			13:35
5: MAC			10
6: MDL			0.01
7: TAP Standing-Cor 105 By Rm 157 Drinking Spout	20-May-17 15:25	21.0	0.02
8: TAP Flushed-Cor 105 By Rm 157 Drinking Spout	20-May-17 16:01	21.0	0.02
9: TAP Standing-Corridor 132 Fountain	20-May-17 15:25	21.0	0.03
10: TAP Flushed-Corridor 132 Fountain	20-May-17 16:01	21.0	0.07
11: TAP Standing-Cor 115 By Rm 129 Drinking Spout	20-May-17 15:25	21.0	0.03
12: TAP Flushed-Cor 115 By Rm 129 Drinking Spout	20-May-17 16:01	21.0	0.10

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical