



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003784
Project #: SFIS #: 4164

02-June-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Leo

Attn : Paul Viszy (PWBS)

Date Rec. : 31 May 2016
LR Report: CA19220-MAY16

535 Paris Rd..
Paris, ON
N3L 3E1,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	02-Jun-16
2: Analysis Start Time		---	10:09
3: Analysis Approval Date		---	02-Jun-16
4: Analysis Approval Time		---	13:15
5: MAC		---	10
6: MDL		---	0.02
7: TAP Standing - Rm 148	28-May-16 07:13	24.1	4.69
8: TAP Flushed - Rm 148	28-May-16 07:48	24.1	1.96

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

Patti Stark
*Project Specialist Environmental Services,
Analytical*