



**SGS Canada Inc.**  
 P.O. Box 4300 - 185 Concession St.  
 Lakefield - Ontario - K0L 2H0  
 Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003680  
**Project #:** SFIS #:3480

02-June-2016

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Brantford**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 31 May 2016  
**LR Report:** CA19233-MAY16

535 Paris Rd..  
 Paris, ON  
 N3L 3E1,

**Copy:** #1

Phone: 519-753-3266  
 Fax:519-753-7072

## CERTIFICATE OF ANALYSIS

### Final Report

| Sample ID                   | Sample Date & Time | Temperature upon Delivery @ London Lab °C | Lead ug/L |
|-----------------------------|--------------------|---|-----------|
| 1: Analysis Start Date      |                    | ---                                       | 02-Jun-16 |
| 2: Analysis Start Time      |                    | ---                                       | 10:09     |
| 3: Analysis Approval Date   |                    | ---                                       | 02-Jun-16 |
| 4: Analysis Approval Time   |                    | ---                                       | 13:19     |
| 5: MAC                      |                    | ---                                       | 10        |
| 6: MDL                      |                    | ---                                       | 0.02      |
| 7: TAP Standing - Room 1080 | 27-May-16 05:01    | 24.1                                      | 2.20      |
| 8: TAP Flushed - Room 1080  | 27-May-16 05:41    | 24.1                                      | 0.64      |

MAC - Maximum Acceptable Concentration  
 MDL - SGS Method Detection Limit

#### Method Descriptions

| Parameter | Description                   | SGS Method Code           | Reference Method Code |
|-----------|-------------------------------|---------------------------|-----------------------|
| Lead      | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 | SM 3030/EPA 200.8     |

**Patti Stark**  
 Project Specialist Environmental Services,  
 Analytical