



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003680
Project : SFIS #:3480

25-July-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Brantford

Attn : Paul Viszy (PWBS)

Date Rec. : 18 July 2017
LR Report: CA19229-JUL17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	24-Jul-17
2: Analysis Start Time		---	16:31
3: Analysis Completed Date		---	25-Jul-17
4: Analysis Completed Time		---	10:06
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 1054 Drinking Spout	13-Jul-17 05:46	24.2	0.04
8: TAP Flushed - Cor 1054 Drinking Spout	13-Jul-17 06:30	24.2	0.05
9: TAP Standing - Cor 1066 Fountain	13-Jul-17 05:46	24.2	0.21
10: TAP Flushed - Cor 1066 Fountain	13-Jul-17 06:30	24.2	0.22
11: TAP Standing - Room 1055 Fountain	13-Jul-17 05:46	24.2	1.70
12: TAP Flushed - Room 1055 Fountain	13-Jul-17 06:30	24.2	0.67

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Units	Description	SGS Method Code
Lead	ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical