



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003836
Project #: SFIS #: 4411

17-May-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Peter
 Attn : Paul Viszy (PWBS)

Date Rec. : 11 May 2016
LR Report: CA15229-MAY16

535 Paris Rd..
 Paris, ON
 N3L 3E1,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	13-May-16
2: Analysis Start Time		---	16:24
3: Analysis Approval Date		--	16-May-16
4: Analysis Approval Time		--	11:16
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing Rm 114	05-May-16 04:46	13.0	1.51
8: TAP Flushed Rm 114	05-May-16 05:21	13.0	0.95

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8



Patti Stark
 Project Specialist Environmental Services,
 Analytical