



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008945

Project : SFIS #: 4429

01-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Pius X

Attn : Paul Viszy (PWBS)

Date Rec. : 26 May 2017

LR Report: CA19253-MAY17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt at London Lab °C	Lead ug/L
1: Analysis Start Date			29-May-17
2: Analysis Start Time			11:00
3: Analysis Approval Date			29-May-17
4: Analysis Approval Time			14:22
5: MAC			10
6: MDL			0.01
7: TAP Standing-Cor 117 By Rm117B D Spout	20-May-17 13:14	21.0	0.01 <MDL
8: TAP Flushed-Cor 117 By Rm 117B D Spout	20-May-17 13:49	21.0	0.01 <MDL
9: TAP Standing-Rm 101 Fountain	20-May-17 13:14	21.0	0.09
10: TAP Flushed-Rm 101 Fountain	20-May-17 13:49	21.0	0.06
11: TAP Standing-Corridor 117 Drinking Spout Across From Rm 126	20-May-17 13:14	21.0	0.01 <MDL
12: TAP Flushed-Corridor 117 Drinking Spout Across From Rm 126	20-May-17 13:49	21.0	0.01 <MDL

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical