



**SGS Canada Inc.**  
P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003706  
**Project #:** SFIS #: 3600

25-May-2016

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) St John's College**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 17 May 2016  
**LR Report:** CA19097-MAY16

535 Paris Rd..  
Paris, ON  
N3L 3E1,

**Copy:** #1

Phone: 519-753-3266  
Fax:519-753-7072

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	20-May-16
2: Analysis Start Time		---	09:19
3: Analysis Approval Date		---	20-May-16
4: Analysis Approval Time		---	12:03
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Rm 2037	15-May-16 06:20	12.1	0.36
8: TAP Flushed - Rm 2037	15-May-16 07:00	12.1	0.07

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

#### Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical