



Works #: 500003706

Project : SFIS #: 3600

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St John's College

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19063-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	11:20
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	14:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 1038 Bot Refill	04-Jun-17 06:03	19.4	0.05
8: TAP Flushed - Cor 1038 Bot Refill	04-Jun-17 06:43	19.4	0.02
9: TAP Standing - Cor 1059 Bot Refill/Vest 1066	04-Jun-17 06:03	19.4	0.05
10: TAP Flushed - Cor 1059 Bot Refill/Vest 1066	04-Jun-17 06:43	19.4	0.02
11: TAP Standing - Cor 1001 Bot Refill by Room 1004	04-Jun-17 06:03	19.4	0.01 <MDL
12: TAP Flushed - Cor 1001 Bot Refill by Room 1004	04-Jun-17 06:43	19.4	0.01 <MDL
13: TAP Standing - Cor 1077 Spout	03-Jun-17 06:08	19.4	0.02
14: TAP Flushed - Cor 1077 Spout	03-Jun-17 06:48	19.4	0.01 <MDL
15: TAP Standing - Cor 1001 Fountain by Rm 1115	03-Jun-17 06:08	19.4	0.01 <MDL
16: TAP Flushed - Cor 1001 Fountain by Rm 1115	03-Jun-17 06:48	19.4	0.01 <MDL
17: TAP Standing - Cor 1059 Spout/Vest 1066	03-Jun-17 06:08	19.4	0.05
18: TAP Flushed - Cor 1059 Spout/Vest 1066	03-Jun-17 06:48	19.4	0.02
19: TAP Standing - Cor 1038 spout/Rm 1044	03-Jun-17 06:08	19.4	0.05
20: TAP Flushed - Cor 1038 spout/Rm 1044	03-Jun-17 06:48	19.4	0.04
21: TAP Standing - Cor 1001 spout/Rm 1004	03-Jun-17 06:08	19.4	0.01 <MDL
22: TAP Flushed - Cor 1001 spout/Rm 1004	03-Jun-17 06:48	19.4	0.02

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Patti Stark
Project Specialist Environmental Services,
Analytical



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003706

Project : SFIS #: 3600

LR Report : CA19063-JUN17

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006