



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003862

**Project :** SFIS #: 4489

19-June-2017

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Theresa**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 06 June 2017

**LR Report:** CA19061-JUN17

174 Stanley St. Unit 300  
Brantford, ON  
N3S 7S3,

**Copy:** #1

Phone: 519-753-3266  
Fax:519-753-7072

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	16-Jun-17
2: Analysis Start Time		---	12:50
3: Analysis Approval Date		---	15-Jun-17
4: Analysis Approval Time		---	09:59
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing-Cor 103 Across Rm 105 Drinking spout	27-May-17 08:55	19.4	0.01
8: TAP Flushed -Cor 103 Across Rm 105 drinking spout	27-May-17 09:30	19.4	0.01 <MDL
9: TAP Standing -Cor 119 Fountain across Rm 125	27-May-17 08:55	19.4	1.25
10: TAP Flushed -Cor 119 fountain across Rm 125	27-May-17 09:30	19.4	0.94
11: TAP Standing -Rm 109	27-May-17 08:55	19.4	1.22
12: TAP Flushed -Rm 109	27-May-17 09:30	19.4	0.30

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical