



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008958
Project : SFIS #: 4319

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Michael Dunnville

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017
LR Report: CA19073-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	13:30
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	16:15
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 102 Drinking Spout	03-Jun-17 13:25	19.4	0.01 <MDL
8: TAP Flushed - Cor 102 Drinking Spout	03-Jun-17 14:00	19.4	0.01 <MDL
9: TAP Standing - Cor 127 Drinking Spout	03-Jun-17 13:25	19.4	0.01 <MDL
10: TAP Flushed - Cor 127 Drinking Spout	03-Jun-17 14:00	19.4	0.01 <MDL
11: TAP Standing - Cor 159 Fountain	03-Jun-17 13:25	19.4	0.01 <MDL
12: TAP Flushed - Cor 159 Fountain	03-Jun-17 14:00	19.4	0.01 <MDL

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



Patti Stark
Project Specialist Environmental Services,
Analytical