



Works #: 500124827

Project : SFIS #: 6104

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2HO  
Phone: 705-652-2000 FAX: 705-652-6365

19-June-2017

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Caledonia**

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19067-JUN17

174 Stanley St. Unit 300  
Brantford, ON  
N3S 7S3,

Copy: #1

Phone: 519-753-3266  
Fax:519-753-7072

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	11:20
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	14:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 144 drinking spout by Rm 163	03-Jun-17 09:26	19.4	0.05
8: TAP Flushed - Cor 144 drinking spout by Rm 163	03-Jun-17 10:01	19.4	0.01 <MDL
9: TAP Standing - Room 165 fountain	03-Jun-17 09:26	19.4	0.37
10: TAP Flushed - Room 165 fountain	03-Jun-17 10:01	19.4	0.25
11: TAP Standing - Cor 121 drinking spout by Room 122	03-Jun-17 09:26	19.4	0.01 <MDL
12: TAP Flushed - Cor 121 drinking spout by Room 122	03-Jun-17 10:01	19.4	0.01 <MDL
13: TAP Standing - Cor 190 spout by Room 165	03-Jun-17 09:26	19.4	0.02
14: TAP Flushed - Cor 190 spout by Room 165	03-Jun-17 10:01	19.4	0.01 <MDL
15: TAP Standing - Room 106 fountain	03-Jun-17 09:26	19.4	0.62
16: TAP Flushed - Room 106 fountain	03-Jun-17 10:01	19.4	0.33

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical