



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500003823

**Project :** SFIS #: 4365

19-June-2017

**PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Patrick Caledonia**

Attn : Paul Viszy (PWBS)

**Date Rec. :** 06 June 2017

**LR Report:** CA19068-JUN17

174 Stanley St. Unit 300  
Brantford, ON  
N3S 7S3,

**Copy:** #1

Phone: 519-753-3266  
Fax:519-753-7072

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	11:20
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	14:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 107 Drinking Spout	03-Jun-17 10:30	19.4	0.02
8: TAP Flushed - Cor 107 Drinking Spout	03-Jun-17 11:05	19.4	0.01 <MDL
9: TAP Standing - Rm 128 Fountain	03-Jun-17 10:30	19.4	0.01 <MDL
10: TAP Flushed - Rm 128 Fountain	03-Jun-17 11:05	19.4	0.01 <MDL
11: TAP Standing - Vest 101 Drinking Spout	03-Jun-17 10:30	19.4	0.01 <MDL
12: TAP Flushed - Vest 101 Drinking Spout	03-Jun-17 11:05	19.4	0.01 <MDL

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Patti Stark**  
Project Specialist Environmental Services,  
Analytical