



Works #: 500009075

Project : SFIS #: 3810

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Bernard of Clairvaux

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19066-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	11:20
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	14:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 102 drinking spout	04-Jun-17 08:48	19.4	0.01 <MDL
8: TAP Flushed - Cor 102 drinking spout	04-Jun-17 09:23	19.4	0.01 <MDL
9: TAP Standing - Cor 129 drinking spout by Rm 130	04-Jun-17 08:48	19.4	0.01 <MDL
10: TAP Flushed - Cor 129 drinking spout by Rm 130	04-Jun-17 09:23	19.4	0.01 <MDL
11: TAP Standing - Cor 129 fountain by Rm 138	04-Jun-17 08:48	19.4	0.01 <MDL
12: TAP Flushed - Cor 129 fountain by Rm 138	04-Jun-17 09:23	19.4	0.01 <MDL

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical