

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500008984**Project :** SFIS #: 3927

21-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Francis of Cabrini**Attn : Paul Viszy (PWBS)****Date Rec. :** 12 June 2017**LR Report:** CA19138-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266

Fax: 519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	20-Jun-17
2: Analysis Start Time		---	10:22
3: Analysis Approval Date		---	20-Jun-17
4: Analysis Approval Time		---	14:40
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor. 2 Drinking Spout	10-Jun-17 06:05	25.4	0.01 <MDL
8: TAP Flushed - Cor. 2 Drinking Spout	10-Jun-17 06:40	25.4	0.01 <MDL
9: TAP Standing - Foyer 12 Drinking Spout	10-Jun-17 06:05	25.4	0.01 <MDL
10: TAP Flushed - Foyer 12 Drinking Spout	10-Jun-17 06:40	25.4	0.01 <MDL
11: TAP Standing - Room 77 Fountain	10-Jun-17 06:05	25.4	0.01 <MDL
12: TAP Flushed - Room 77 Fountain	10-Jun-17 06:40	25.4	0.01 <MDL
13: TAP Standing - Cor. 42 Drinking Spout by Room 48	10-Jun-17 06:05	25.4	0.01 <MDL
14: TAP Flushed - Cor. 42 Drinking Spout by Room 48	10-Jun-17 06:40	25.4	0.01 <MDL

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
Project Specialist Environmental Services,
Analytical