



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500003745
Project #: SFIS #: 3660

10-May-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Sacred Heart

Attn : Paul Viszy (PWBS)

Date Rec. : 04 May 2016
LR Report: CA15054-MAY16

535 Paris Rd..
Paris, ON
N3L 3E1,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	09-May-16
2: Analysis Start Time		---	10:33
3: Analysis Approval Date		--	09-May-16
4: Analysis Approval Time		--	12:00
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing Room 119	01-May-16 10:56	11.0	7.33
8: TAP Flushed Room 119	01-May-16 11:36	11.0	2.86

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

Patti Stark
Project Specialist Environmental Services,
Analytical